

**CITY OF NEWTON, MASSACHUSETTS  
PURCHASING DEPARTMENT**

**ADDENDUM #1**

***REQUEST FOR PROPOSAL #05-77***

**Operation & Maintenance of Water and Wastewater  
Pumping / Storage Facilities**

*June 9, 2005*

**PLEASE NOTE:**

**This addendum is to: Answer the following questions.**

**Q #1.** What is the current City's maintenance management software program(s) listed in the evaluation criteria?

**A#1. Maintenance : HANSEN IMS VER 7.7 & SCADA : INTELLUTION**

**Q #2.** The RFP does not list the licenses required by the DEP. What license(s) is required for Wastewater?

**A #2.** Grade 4 Municipal & Grade 4 Collection System (voluntary)

**Q #3.** What license(s) is required for Water?

**A #3.** Grade 4 Distribution

**Q #4.** Are there approved staffing plans for wastewater system and water system available for review?

**A #4.** Not at this time, but the City will try to make those available prior to submission.

**Q #5.** Is the GIS map of the Water, Sewer and Storm Drainage System available to the proposers?

**A #5. Yes, copies will be available in the Purchasing dept. on June 10, 2005 for pickup.**

All other terms and conditions of this bid remain unchanged

***PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR PRICE PROPOSAL***

Thank you.  
Re Cappoli  
*Chief Procurement Officer*