

CITY OF NEWTON, MASSACHUSETTS

PURCHASING DEPARTMENT
purchasing@newtonma.gov
Fax (617) 796-1227

February 1, 2010

ADDENDUM #1 INVITATION FOR BID #10-42

Annual - Sewer System Rehabilitation Contract

THIS ADDENDUM IS TO: **Answer the following Questions:**

Q1. How will cleaning levels be determined.

A1. Anytime there is the need to make more than two (2) passes with the high pressure cleaner, It will be considered heavy cleaning under the contract.

Q2. Where were accumulated solids disposed of in prior contract?

A2. Contractor was responsible for the disposal of solids in the prior contract.

Q3. What type of pipe material is the majority of the work going to be done on? ie: vcp, pvc, ac?

A3. VCP

Q4. Will there be a pre bid meeting?

A4. No

Q5. Will the city supply hydrants in all work areas for cleaning?

A5. Yes

Q6. Will there be any access issues? ie: easements or manholes that can not be accessed?

A6. No

All other terms and conditions of this bid remain unchanged

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM

Thank you,



Re Cappoli
Chief Procurement Officer